



**NOTES:**

1. ALL GATE VALVES SHALL BE OF RESILIENT WEDGE TYPE CONFORMING TO AWWA C515 STANDARDS.
2. VALVES SHALL BE LEFT HAND OPENING (COUNTER-CLOCKWISE).
3. GATE VALVE ADAPTER SHALL BE MANUFACTURED BY ADAPTOR INC., OR APPROVED EQUAL.
4. GATE VALVE AND BOXES SHALL BE TYLER SERIES 6860, STAR PIPE PRODUCTS SERIES, MUELLER NO. H-10357, OR APPROVED EQUAL.
5. ALL BOLTS INCLUDING T-BOLTS SHALL BE COR-BLU.
6. GATE VALVE AND BOX SHALL BE STRAIGHT, ALLOWING A 4" PVC PIPE TO SLIDE DOWN THE BOX AND OVER THE GATE OPERATING NUT.

DESIGN:	DATE:	 <b>ENGINEERING DEPARTMENT</b> <b>GATE VALVE AND BOX</b> <b>INSTALLATION</b>	PLATE NUMBER
DRAWN:			W-5
REVISIONS	06-11-2020		